

EN 14904:2006 - Slip Test Work Sheet

Date of Test	2012-05-25
Operator	Erik Fosstveit
Slip Tester Calibration No.	C2418
Slip Tester Serial No.	SK1692
Date of Calibration	2012-05-16
Slider Type	CEN

Test Location	Bona Laboratory, Malmö
Substrate Description	WT1553
Date of Substrate Coating	2012-04-11
Contaminate Description	N/A
Surface Temperature	N/A

EN 14904:2006 requirement: 80-110 PTV

Traffic HD Silk matt					
Result	1	2	3	4	5
Measurement	90	86	88	86	86
PTV:	87				

Traffic HD Matt					
Result	1	2	3	4	5
Measurement	89	89	90	91	91
PTV:	90				

Traffic HD Extra Matt					
Result	1	2	3	4	5
Measurement	94	92	92	91	91
PTV:	92				

Bona[®]